



		<b>Project Title</b> <b>SUDDATH GLOBAL LOGISTICS, LLC</b> <b>PROPOSED FTZ SITE</b>		<b>Orientation</b> 	
<b>Facility Address</b> 11001 Pritchard Rd. Jacksonville, FL 32219		<b>Version</b> 2	<b>Document Number</b> N/A	<b>Scale</b> See Legend	
		<b>Last Updated</b> 8/12/2014	<b>Updated By</b> Donald Sheldon		

**LEGEND**

- █ Parcel Boundary of Proposed Site
- █ Parcel Boundaries of Surrounding Area

Zone Type: PUD

11.75 Acres

**SCALE**



Imagery and Data Copyright City of Jacksonville  
 Map by Donald Sheldon

**FIRE SYSTEM SPECIFICATIONS**

Wet pipe system
Fire Pump: Patterson 8x6 WT, 1500gpm @ 95 psi
Fire Pump: start @ 140 psi, stop @ 175 psi
Jockey Pump: start @ 150 psi, stop @ 170 psi
3/4" ESFR Sprinkler Heads
4 risers
Static pressure at all risers: 160 psi